



PXP Low Ash 40W Natural Gas Compressor Oil

PXP Low Ash 40W Natural Gas Compressor Oil

Permian Production Lubricants' Gas Compressor Oil is a technologically superior lubricant for oil-flooded rotary compressors in natural compressors situated in harsh oilfield environments. Our technology rich blend Carries a low Total Acid Number (TBN) of .50 and it's Sulfated Ash tests at .47 making it among the very best in class in these two qualifying attributes. Further, due to the cationic technology included, our stationary gas compressor oils deliver a powerful thin film that protects against wear, reduces heat & triction, while it repels moisture, corrosion, varnish, and sludge. These behaviors increase efficiency, operating life span, and performance.

The Permian Extreme Pressure (PXP) additive package delivers unmatched lubricant film-to-metal pressure, friction, and corrosion protection through it's positive-charged (+) technology, which is attracted and bonds to metal's negatively charged (-) surfaces laying down a powerful EP film barrier between metal surfaces and other high pressure metal contact points, fluids, elements, solids, abrasives, and friction.

SB-C9GC is formulated to provide the highest protection against oxidation, corrosion, heat, moisture, wear, gas dilution, and hydrocarbon solubility, while increasing the efficiency lifespan of stationary gas compression assets and is available in a wide range of ISO viscosity requirements.

Features & Benefits

- Complete Range of ISO Viscosity Requirements
- Low Starting TAN at .50
- Sulfated Ash Test at .47
- Extreme Friction Reduction
- Increased Oil Drain Intervals by 25% to 40%
- Positive Charged (+) lubricant Creates thin lubricant film bond to metal surfaces and contact points.
- Repels & Displaces Moisture
- Resists Thermal Degradation
- Strong Oxidation & Corrosion Inhibitor
- Resists Sludge, Varnish, Foam, & Emulsification
- Superior Wear Protection
- Extreme Service Life
- Minimizes Gas Dilution & Oil Absorption Effects
- High Load Carry
- Extends Equipment Life

Test Results

Data	Permian Production Lubricants LA40
SAE	40
Viscocity Index	101
Viscocity (40C)	127.6
Viscocity (100C)	14.1
Sulphated Ash%	0.474
TAN	0.5
TBN	4.5
Calcium (% wt)	0.123
Zinc (% wt)	0.034
Phosphorus (% wt)	0.031

MEETS OR EXCEEDS SPECS FOR

- Cummins
- MWM
- Mann
- Dresser Rand

- Wartsila 4T
- Caterpillar
- Waukesha
- Jenbacher





Printed on: 10 Nov 2020

APEX OIL LAB

Location: Main > P > Permian Production Lubricants > New Oil Baselines

Unit ID: Premium 40w

Model:

Machine Type: Engine



Data for customer review.

Limited diagnosis due to Data Sheet not provided.

S Anj. 10 Nov 2020

				918503		
il Unknown Eng	ine	Sample ID		U29217		
Note:		Sampled on		06 Nov 2020		
		Received on		06 Nov 2020		
		h/m Total				
		h/m Oil				
		Top up (l.)				
		_ (Warning Limits	٥		
	Iron	ррт	0 - 150	1	. (//) .	
	Chrome	ррт	0 - 10	<1		
	Nickel	дрт		<1		
	Molybdene	ррт		2		
ASTM D6595-00	Aluminium	дрт	0 - 20	1		
WEAR METALS	Lead	ррт	0 - 25	<1		
	Copper	ррт	0 - 120	<1		
	Tin	дрт	0 - 10	<1		
	Silver	ррт		<1		
	Titanium	ррт		<1		
	Silicon	дрт	0 - 25	3		
ASTM D6595-00	Sodium	ррт	0 - 15	5		
CONTAMINANT	Vanadium	дрт		<1		
s	Potassium	ррт		- 5		
	Lithium	ррт		<1		
	Calcium	дрт		1020		
	Magnesium	дрт		- 8		
	Phosphorus	ррт		231		
	Zinc	дрт		288		
	Barium	ррт		<1		
	Boron	дрт		3		
MET-MEC-005	Fuel dilution	%		0.00		
ASTM D445	Viscosity at 100°C	cSt		13.8		
ASTM E2412	TAN	mg KOHilg	0.00 - 5.00	0.50		
	TBN	mg KOHig	<2.00	5.30		
	WaterPPM	ррт		14.3		
	Oxidation By-Products	Abs/0.1mm		0.0		
	Nitration By-Products	Abs/0.1mm		0.0		
	Sulfation By-Products	Abs/0.1mm		0.0		
	Glycol	%	0.0 - 0.5	0.0		

Date 10 Nov 2020

Page 1 of 1



CERTIFICATE OF ANALYSIS

Apex Oil Lab 3876 East Paris Ave SE Suite 11

Grand Rapids, MI 49512 Attn: Jason Rainey Report Date: 11/25/2020 Laboratory Number: A201124004 Sample Type: Oil

Sample ID: Permian Production Lubricants Premium LA40

 Tests Requested
 Result
 Unit
 Method

 Suffered Ash
 0.474
 Wt%
 ASTM D874

Report Prepared by,

Sophia Phanthamany, Lab Technician

Reviewed and Approved by,

Stuart Ramsdale, Lab Manager